



0.45

2.00

0.2

Concrete widening
0.2m tk (min)

PLAN
SCOUR VALVE

Not to Scale

NOTES:

1. All dimensions are in metres unless otherwise shown.
2. Concrete to be 32MPa and in accordance with AS. 1379 and AS. 3600.
3. Reinforcement to be in accordance with AS. 1304.
4. All flanges to be in accordance with AS. 2129 – Table C U.N.O.
5. Scour Valve marker posts to be installed in accordance with CMDM Dwg SD-W-060-LSC.
6. Precast Reinforced Concrete Chamber components to be Humes 1050 Access Chamber Epoxy Jointed or similar approved equivalent.
7. RC Convertor Slab, RC Surround & CI Cover to be rotated to provide optimum access to pit.
8. RC Surround to be supplied with Cast Iron frame to suit solid Cast Iron bolt down San Sew Cover.
9. Where foundation bearing pressure is less than 50 kPa, excavate and replace unsatisfactory material with compacted CBR15 material to the depth ordered by the Works Supervisor.

REVISIONS		APPROVED	RPEQ	DATE	<p>DISCLAIMER.</p> <p>The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, of consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.</p>	<p>Capricorn Municipal Development Guidelines</p> <p>Incorporating: Rockhampton City Council Livingstone Shire Council Fitzroy Shire Council Mount Morgan Shire Council</p>		<p>SCOUR VALVE CONSTRUCTION DETAILS</p> <p>Livingstone Shire Council</p>		STANDARD DRAWING SD-S-073-LSC								
A	ORIGINAL ISSUE		5424	2/2/07														
REV.													A					