



NOTES:

1. Concrete S32 in accordance with AS 1379 and AS 3600.
2. Reinforcement fabric to AS 1304.
3. Stainless steel Grade AS 2837/316.
4. Polythene pipework to AS 1159.
5. Aluminium Sheet 5083-H321, Extruded sections 6061-T6, to AS 2848.
6. All dimensions in millimetres.

REVISIONS		APPROVED	RPEQ	DATE	<p align="center">DISCLAIMER.</p> <p>The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, of consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.</p>	<h2 align="center">Capricorn Municipal Development Guidelines</h2> <p>Incorporating:</p> <ul style="list-style-type: none"> Rockhampton City Council Livingstone Shire Council Fitzroy Shire Council Mount Morgan Shire Council 	<h1 align="center">BACKFLOW PREVENTION DEVICE SLAB MOUNTED CUBICLE</h1> <p align="center">Livingstone Shire Council</p>	STANDARD						
								DRAWING						
B	LSC ALTERATIONS	D.T.	5424	06/04/06				SD-W-030-LSC						
A	ORIGINAL ISSUE													
							REV.	A	R					