

Memorandum

To: Donna Ward, DEPOT FINANCIAL SERVICES SUPERVISOR

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 29 August 2007

Re: Purchase Specification – Precast Sewerage Access Chamber Components – Rev A.

File Reference: pm:kb 50/001/0028

PRECAST SEWERAGE ACCESS CHAMBER COMPONENTS.

PURCHASE SPECIFICATION.

- 1.0 Precast Sewerage Access Chamber components are to be in accordance with Australian Standard AS 4198 – Precast Concrete Access Chambers for Sewerage Applications.
- 2.0 Information to be nominated at time of purchase – nominal internal diameter, type of components, access cover & frame unit details, pipeline type, component joint type.
- 3.0 Cover & Frame details refer to Council Purchase Specification – Access Chamber Covers & Frames for Water Supply & Sewerage. Details required are: load class, shape, material type, fastening device, marking. Access covers and frames shall be 'M' or 'H' (Class C or D) as nominated.
- 4.0 Step irons and ladders are not required.
- 5.0 Joints between components will be 'mastic' or 'epoxy' type, as nominated.
- 6.0 Product certification in accordance with AS 4198.

Prepared by
Phil McKone RPEQ
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon RPEQ
EXECUTIVE MANAGER COMMERCIAL SERVICES.