

Memorandum

To: Alan Auld, PURCHASING OFFICER - STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 08 June 2004

Re: Purchase Specification – Spring Hydrant Valve for Waterworks Purposes.

File Reference: pm:kb 50/001/0028

SPRING HYDRANT VALVE FOR WATERWORKS PURPOSES

PURCHASE SPECIFICATION.

- 1.0 Spring Hydrants are to be in accordance with Australian Standard AS 3952 - Water Supply - Spring Hydrant Valve for Waterworks Purposes.
- 2.0 Class 16 pressure rating (min. working 1200 kPa), buried conditions.
- 3.0 DN100 Flanges – AS4087 DN100 (compatible with Table C of AS 2129).
- 4.0 Dome to be of gunmetal material.
- 5.0 Fasteners to be of stainless steel.
- 6.0 Internal and external surfaces to have polymeric coating in accordance with AS/NZS 4158.
- 7.0 Product certification in accordance with AS 3952.

Prepared by
Phil McKone
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon
EXECUTIVE MANAGER COMMERCIAL SERVICES.