

Memorandum

To: Donna Ward, DEPOT FINANCIAL SERVICES SUPERVISOR

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 13 June 2006

Re: Purchase Specification – PVC Sewer Pipe and Fittings, Rev A.

File Reference: pm:kb 50/001/0028

PVC-U SEWER PIPE AND FITTINGS.

PURCHASE SPECIFICATION.

- 1.0 PVC Gravity Sewer Pipes and Fittings for municipal sewer mains are to be in accordance with Australian Standard AS/NZS 1260 – PVC-U Pipes and Fittings for Drain, Waste and Vent Applications.
- 2.0 Pipe size (DN), Stiffness Class (SN), and socket type will be nominated at time of purchase.
- 3.0 Stiffness Class (SN) –

Less than 3m deep	-	SN 8;
Equal to or greater than 3m deep	-	SN 10;
All pipe 225mm diameter or greater	-	SN 10.
- 4.0 Pipe will be installed in accordance with AS2033.
- 5.0 Product certification in accordance with AS/NZS 1260.

Prepared by
Phil McKone RPEQ
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon RPEQ
EXECUTIVE MANAGER COMMERCIAL SERVICES.