

# **Memorandum**

---

**To: Alan Auld, PURCHASING OFFICER – STORES**

---

**From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES**

---

**cc:**

---

**Date: 30 September 2004**

---

**Re: Purchase Specification – Polyethylene Sleeving for Ductile Iron Pipes.**

---

**File Reference: pm:kb 50/001/0028**

---

## **POLYETHYLENE SLEEVING FOR DUCTILE IRON PIPES.**

### **PURCHASE SPECIFICATION.**

- 1.0 Polyethylene sleeving for ductile iron (DICT) pipes is to be in accordance with Australian Standard AS 3680 - Polyethylene Sleeving for Ductile Iron Pipe.
- 2.0 Installation of the sleeving will be in accordance with AS 3681.
- 3.0 Size of the sleeving will be specified at time of purchase and be designated by the applicable pipe nominal size.
- 4.0 Colour of the sleeving will be specified at time of purchase and be designated by the applicable pipe use being:

water supply	-blue
raw sewage	-cream
treated effluent recycling	-lilac
- 5.0 No perforations.
- 6.0 Product certification in accordance with AS 3680.

Prepared by  
Phil McKone

**STRATEGIC ASSETS AND COMPLIANCE ENGINEER.**

Endorsed by  
Dan Toon

**EXECUTIVE MANAGER COMMERCIAL SERVICES.**