

# **Memorandum**

---

**To:** Donna Ward, DEPOT FINANCIAL SERVICES SUPERVISOR

---

**From:** Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

---

**cc:**

---

**Date:** 26 July 2006

---

**Re:** Purchase Specification – Detectable Marker Tape – Rev A.

---

**File Reference:** pm:kb 50/001/0028

---

## **DETECTABLE MARKER TAPE FOR PIPELINES**

### **PURCHASE SPECIFICATION.**

- 1.0 Detectable Marker Tape is to be in accordance with Australian Standard AS 2648 – Underground Marking Tape.
- 2.0 Background colours to be in accordance with Australian Standard AS 1345 – Identification of the contents of pipes, conduits and ducts.
- 3.0 Tape width to be at least 100mm.
- 4.0 Tracer wire to be: at least 0.5mm diameter, stainless steel material, and be detectable by pipeline locators.
- 5.0 Background colour and wording (black letters) to be as follows:

Buried Potable Water Main Below	-	Green or Dark Blue background
Buried Recycled Water Main Below	-	Lilac background
Buried Sewer Main Below	-	Cream or Grey background
- 6.0 Product certification in accordance with AS 2648.
- 7.0 Pipeline type will be specified at the time of purchase enquiry.

Prepared by  
Phil McKone RPEQ  
**STRATEGIC ASSETS AND COMPLIANCE ENGINEER.**

Endorsed by  
Dan Toon RPEQ  
**EXECUTIVE MANAGER COMMERCIAL SERVICES.**