

Memorandum

To: Alan Auld, PURCHASING OFFICER – STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 08 June 2004

Re: Purchase Specification – Brass Gate Valves, Brass Globe Valves & Brass Non-Return Valves.

File Reference: pm:kb 50/001/0028

BRASS GATE VALVES, BRASS GLOBE VALVES & BRASS NON-RETURN VALVES

PURCHASE SPECIFICATION.

- 1.0 Brass gate valves, brass globe valves and brass non-return valves are to be in accordance with Australian Standard AS 1628 - Water Supply – Metallic Gate, Globe and Non-Return Valves.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally below-ground conditions.
- 3.0 All copper alloy components are to be Dezincification-Resistant (DR).
- 4.0 Gate valves to be clockwise closing.
- 5.0 Non-return valves to be 'swing' type.
- 6.0 Product certification in accordance with AS 1628.
- 7.0 Purchaser to specify nominal size and end connection arrangement.

Prepared by
Phil McKone
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon
EXECUTIVE MANAGER COMMERCIAL SERVICES.