

Memorandum

To: Alan Auld, PURCHASING OFFICER – STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 20 October 2004

Re: Purchase Specification – Sewerage Vent Pole.

File Reference: pm:kb 50/001/0028

SEWERAGE VENT POLE.

PURCHASE SPECIFICATION.

- 1.0 Sewerage vent poles are to be used at all sewage pump stations and sewage discharge manholes.
- 2.0 Hot dipped galvanised mild steel round tapered pole type.
- 3.0 Terrain Category 2, Wind Region C.
- 4.0 6m length, 1 piece (no sections).
- 5.0 Base plate mounted.
- 6.0 100mm ID at pole top.
- 7.0 Complete with access door.
- 8.0 Complete with galvanised foundation reinforcing cage and bolts.

Prepared by
Phil McKone RPEQ
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon RPEQ
EXECUTIVE MANAGER COMMERCIAL SERVICES.