

PS-19**CMDG PURCHASE SPECIFICATION.****SEWERAGE VENT POLE.**

- 1.0 Sewerage vent poles are to be used at all sewage pump stations and sewage discharge manholes.
- 2.0 Hot dipped galvanised mild steel round tapered pole type.
- 3.0 Wind Class C2.
- 4.0 6m length, 1 piece (no sections).
- 5.0 Base plate mounted.
- 6.0 100mm ID at pole top.
- 7.0 Complete with access door.
- 8.0 Complete with galvanised foundation reinforcing cage and bolts.
- 9.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.