

**PS-10****CMDG PURCHASE SPECIFICATION.****TAPPING BANDS FOR PIPELINES**

- 1.0 Tapping Bands are to be used for water service connections to all water pipelines.
- 2.0 Size and pipe type will be specified at time of purchase.
- 3.0 Installed in below-ground conditions.
- 4.0 Pressure rating of 1200 kPa.
- 5.0 Castings, nuts and integral studs are to be only gunmetal material in accordance with AS 1565 - Copper and Copper - Alloys Ingots and Castings.
- 6.0 Seal to be a 'V' shape - pressure assisted seal type. Not an 'O-Ring'.
- 7.0 Tapings to be in accordance with AS1722.1 - Sealing Pipe Threads.(BSP Threads).
- 8.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.