

PS-12**CMDG PURCHASE SPECIFICATION.****BRASS GATE VALVES, BRASS GLOBE VALVES & BRASS NON-RETURN VALVES**

- 1.0 Brass gate valves, brass globe valves and brass non-return valves are to be in accordance with Australian Standard AS 1628 - Water Supply – Metallic Gate, Globe and Non-Return Valves.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally below-ground conditions.
- 3.0 All copper alloy components are to be Dezincification-Resistant (DR).
- 4.0 Gate valves to be clockwise closing.
- 5.0 Non-return valves to be 'swing' type.
- 6.0 Product certification in accordance with AS 1628.
- 7.0 Purchaser to specify nominal size and end connection arrangement.
- 8.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.