

PS-15**CMDG PURCHASE SPECIFICATION.****SINGLE DETECTOR CHECK VALVE.**

- 1.0 Valve size will be nominated at time of purchase.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally above-ground conditions.
- 3.0 No bypass required.
- 4.0 End connections to be double flanged.
- 5.0 Flanges to be AS2129 Table 'C' or 'E'.
- 6.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.