

PS-7**CMDG PURCHASE SPECIFICATION.****POLYETHYLENE SLEEVING FOR PIPES.**

- 1.0 Polyethylene sleeving for pipes is to be in accordance with Australian Standard AS 3680 - Polyethylene Sleeving for Ductile Iron Pipe.
- 2.0 Installation of the sleeving will be in accordance with AS 3681.
- 3.0 Size of the sleeving will be specified at time of purchase and be designated by the applicable pipe nominal size.
- 4.0 Colour of the sleeving will be specified at time of purchase and be designated by the applicable pipe use being:

water supply	-blue
raw sewage	-cream
treated effluent recycling	-lilac
- 5.0 No perforations.
- 6.0 Product certification in accordance with AS 3680.
- 7.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.