

PS-9**CMDG PURCHASE SPECIFICATION.****DETECTABLE MARKER TAPE FOR PIPELINES**

- 1.0 Detectable Marker Tape is to be in accordance with Australian Standard AS 2648 – Underground Marking Tape.
- 2.0 Background colours to be in accordance with Australian Standard AS 1345 – Identification of the contents of pipes, conduits and ducts.
- 3.0 Tape width to be at least 100mm.
- 4.0 Tracer wire to be: at least 0.5mm diameter, stainless steel material, and be detectable by pipeline locators.
- 5.0 Background colour (with wording black letters) to be as follows:

Buried Potable Water Main Below	-	Dark Blue
Buried Recycled Water Main Below	-	Lilac
Buried Sewer Main Below	-	Cream or Grey
- 6.0 Product certification in accordance with AS 2648.
- 7.0 Pipeline type will be specified at the time of purchase enquiry.
- 8.0 This specification takes precedence, but where this specification is silent on a matter then the order of priority for reference shall be the relevant Australian Standard, and then the relevant WSAA Purchase Specification.