



DOOR AND LOUVRE SCHEDULE

ITEM	DESCRIPTION	No.Off
D1	Nominal 2200 high x 900 wide acoustic door externally faced with 1.6mm galvanised steel sheet metal, with 1.6mm thick pressed galvanised steel welded door frame, three 100mm heavy duty stainless steel hinges and "Lockwood - 303" single cylinder dead lock. Provide internal and external door handles. Door and frame is to be painted with an approved gloss enamel paint system. Colour is to be advised.	1
D2	Nominal 2200 high x 2000 wide 2 leaf factory hung acoustic door with suitably designed heavy duty galvanised steel frame with stainless steel sill, and purpose designed adjustable heavy duty ball bearing hinges. Doors shall be externally faced with 1.6mm galvanised steel sheet. Both leaves to be fitted with satin chrome shoot bolts top and bottom. Top shoot bolts shall extend down to 1800 above floor level. Provide internal and external door handles. Door and frame is to be painted with an approved gloss enamel paint system. Colour is to be advised.	1
D3	Nominal 2200 high x 1800 wide 2 leaf factory hung acoustic door with suitably designed heavy duty galvanised steel frame with stainless steel sill, and purpose designed adjustable heavy duty ball bearing hinges. Doors shall be externally faced with 1.6mm galvanised steel sheet. Both leaves to be fitted with satin chrome shoot bolts top and bottom. Top shoot bolts shall extend down to 1800 above floor level. Provide internal and external door handles. Door and frame is to be painted with an approved gloss enamel paint system. Colour is to be advised.	1
W1	Nominal 800 high x 1200 wide powder coated aluminium weather/insect-proof acoustic louvres. Colour is to be anodized bronze. (ACRAN 200 Series or equivalent)	3

THIS STANDARD DRAWING IS A GUIDE ONLY AND SHOULD NOT BE USED FOR DESIGN PURPOSES

- NOTES:**
 1. ALL CABLING WITHIN THE BUILDING TO BE OVERHEAD ON CABLE TRAYS.
 2. REDESIGN OF STRUCTURAL COMPONENTS WILL BE REQUIRED FOR EACH SPECIFIC LOCATION.

APPLICABILITY TABLE								
Council	BSC	CHRC	GRC	IRC	LSC	MRC	RRC	
Applicable	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

REVISIONS	DATE	
I	STRUCTURAL DETAILS REMOVED	03/2017
H	IRC ADDED	11/2016
G	GRC AND LSC ADDED	09/2014
F	DIMENSION AMENDMENTS	08/2014
E	POST AMALGAMATION REVIEW	01/2013
D	BANANA SHIRE COUNCIL ADDED	09/2007
C	CMDG REVIEW CHANGES	04/2007
B	REVISED ISSUE	02/2007
A	ORIGINAL ISSUE	10/2003

DISCLAIMER.
 The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, of consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.

Capricorn Municipal Development Guidelines
 Incorporating:
 Banana Shire Council (BSC) Livingstone Shire Council (LSC)
 Central Highlands Regional Council (CHRC) Maranoa Regional Council (MRC)
 Gladstone Regional Council (GRC) Rockhampton Regional Council (RRC)
 Isaac Regional Council (IRC)

STANDARD WATER SUPPLY BOOSTER PUMP INSTALLATION ELEVATION

WATER						
STANDARD DRAWING						
CMDG-W-073						
REV.	A	B	C	D	E	F