

Ø12 approved SS masonry anchor

Galvanised steel tube to suit spindle

40x6 galvanised steel, Grade Hd200 to AS 1594.

- Refer Standard Drawings CMDG-S-020 and CMDG-S-021 for details of access chambers and covers.
- Where foundation bearing pressure is less than 50kPa, excavate and replace unsatisfactory material with compacted CBR15 material to the depth ordered by the Superintendent.
- Concrete N25 in accordance with AS 1379 and AS 3600.
- All welds to AS 1554. All welding symbols to AS 1101.3. The location of the scour valve and extent of scour discharge pipe are
- indicated on project drawings.
- All dimensions in millimetres.
- The purpose of the scour system is to release water and remove any sedimentation that maybe in the water reticulation network.

APPLICABILITY TABLE								
Council	BSC	CHRC	GRC	IRC	LSC	MRC	RRC	
Applicable	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
OUR DETAILS					WATER			
					STANDARD DRAWING			A3
					CMDG-W-080			
					REV. B C D E F G			